



City of Wilton Manors
Finance Department
2020 Wilton Drive
Wilton Manors, FL 33305

Ariel Montalvo
Phone (954) 390-2171
Fax (954) 390-2199
www.wiltonmanors.com

Addendum No. 2

ITB for Fire Station Generator
Addendum Release Date December 17, 2025

ITB # 2026-03

ITB Due Date/Time: ~~December 29, 2025, 2:30 p.m., EST~~ **New Due Date: January 27, 2026, 2:30 p.m., EST**

Submit To: City Clerk
City of Wilton Manors
2020 Wilton Drive
Wilton Manors, Florida 33305

The purpose of this Addendum is to answer questions received from potential proposers. These are questions that were received prior to the published deadline for questions of December 8, 2025.

IMPORTANT NOTE – the following is added to ITB # 2026-03. It is the Proposer's responsibility to use the revised information when preparing the response.

The questioning period will re-open and close on December 31, 2025, at 7:00 a.m. Addendum No. 2 and questions received through the closing period and questions that have been previously received will be answered on or before January 13, 2026.

Q1: We are asking to see if you accept 60kW Blue star power systems generator with a John Deere engine, Deep sea controller, and Stamford alternator.

A: Our specs call out three (3) acceptable generator manufacturers, and we typically do not evaluate substitutions during bidding. The contractor may offer a substitute manufacturer during construction through the shop drawing submittal process. He does so at his own risk since the substitution may be deemed unacceptable.

Q2: Does the City have engineer drawings & elevation certificates for each location or will it be the contractors' responsibility to get site elevation certificates and drawings for permitting?

A: It is the contractors' responsibility to get site elevation certificates and drawings for permitting.

Q3: Do existing generator slab elevations meet new Broward county 100-year flood elevations? If not, slabs must be elevated.

A: Contractor will need to confirm if the existing generator slab elevations meet Broward County 100-year flood elevation.



City of Wilton Manors
Finance Department
2020 Wilton Drive
Wilton Manors, FL 33305

Ariel Montalvo
Phone (954) 390-2171
Fax (954) 390-2199
www.wiltonmanors.com

Q4: Please explain item # 12 as there are no drawings, if this is to be part of the bid, a site visit will be required to understand the scope. We would also need questions extended until a few days after the site visits.

A: *City to coordinate site visits, as requested, for contractors. No drawings are provided for this bid. Extension for site visits and questions was provided.*

Q5: What are we to do with the old equipment?

A: *Contractor to coordinate with the City for disposal/salvaging of the old equipment.*

Q6: Who is responsible for the removal of the existing fuel?

A: *The City will coordinate removal of the existing fuel.*

Q7: Are there Davis bacon wages? If so please publish.

A: *No.*

Q8: Is there to be a new remote annunciator? If so, where is it to be located? Is there one currently where the existing conduit can be reused?

A: *No remote annunciator.*

Q9: Please confirm that back up power will be required for each ATS installation which will take 6-8 hours each?

A: *Yes.*

End of Addendum # 2